


Notes:

1. Meter Pit, Frame And Cover, And Customsetter Shall Be Furnished And Installed By The Contractor.
2. 2" Corporation AWWA Taper Threads Shall Be Installed As Detailed On Standard No. W-7.01.
3. Mueller Part Numbers For 1 1/2" And 2": B-2423--2-01.
4. Reinforced Coated Tracer Wire As Manufactured By Copperhead Industries, LLC, P.O. Box 1081, Monticello, MN, 55362, Or An Approved Equal.
5. Thoroughly Tape Mechanical Connections With Electrical Tape.

APPROVAL	REVISED	TOWN OF EASTON AND EASTON UTILITIES STANDARD DETAILS 1 1/2" AND 2" METER INSTALLATION
 EU MANAGER OF ENGINEERING DATE	AUG 1, 94	
	MAY 3, 95	
	MAR 1, 98	
	FEB 1, 06	
	MAR 1, 07	
ISSUED: MAY 1, 1986	SEP 1, 09	STANDARD NO. W-7.03